



1200 Old Trenton Road, West Windsor, NJ 08550

Purchasing Department

Phone: 609-570-3253

Email: [purchasing@mccc.edu](mailto:purchasing@mccc.edu)

## MCCC RFB #25-03 – ROAD LIGHTING IMPROVEMENTS ADDENDUM #1

May 23, 2025

Mercer County Community College is issuing this Addendum #1 on May 23, 2025 for RFB #25-03 for the ROAD LIGHTING IMPROVEMENTS project. The following information shall serve to clarify and amend certain items from the initial solicitation publicly advertised on May 15, 2025.

MCCC RFB #2503 bid documents are available for download using the link below:

<https://clarkecatonhintz.sharefile.com/share/getinfo/sedf4b72c01224275a349a04b853e3ecb>

The last day for submitting questions/clarifications for this RFB solicitation is May 29, 2025 at 2:00 P.M. prevailing time. The Bid Submission Due date is June 16, 2025 at 2:00 P.M. prevailing time.

**Please note: The bid opening location has been updated. The new location is:  
UC 100, University Center, Mercer County Community College,  
1200 Old Trenton Road, West Windsor, NJ**

QUESTION / ISSUE	ANSWER
<b>Q1.)</b> I have noticed the NJDPMC acceptable codes for bidding the project are C008 & C009. We are an electrical contractor with a code of C047. We have done a number of highway and private lighting projects as a prime. HBC is respectfully requesting you add the C047 code as an acceptable prequalification.	<b>A1.)</b> DPMC C047 qualifications are acceptable. See Revised 004113 Form of Proposal (Bid Form): revised to add DPMC C047 classification.
<b>Q2.)</b> Addition of one (1) Engineering drawing.	<b>A2.)</b> SP-18, [Lighting Plan], 4/25/2024: Newly added drawing.
<b>Q3.)</b> Email address correction.	<b>A3.)</b> The correct email address is: <a href="mailto:hpahuja@cchnj.com">hpahuja@cchnj.com</a>

<b>Q4.)</b> Is the awarded vendor expected to purchase the light fixtures?	<b>A4.)</b> No, the fixtures have been purchased by the College, and are currently housed in a Warehouse behind the Maintenance Building. They will need to be moved by the awarded vendor to the necessary site(s).
<b>Q5.)</b> What are the number of light fixtures needed for this project?	<b>A5.)</b> Thirty-one (31) fixtures are for the main project at the West Side of campus, and (twenty-nine) 29 fixtures are for at the alternate project at the East Side of campus.
<b>Q6.)</b> Will new pedestals be needed for the fixtures?	<b>A6.)</b> Yes, new pedestals will need to be poured once the old pedestals have been demolished and removed. The demo and removal will be handled by the awarded vendor.
<b>Q7.)</b> Updated bid opening location	<b>A7.)</b> Revised 001113 Public Notice to Vendors to show change in room to UC100, University Center

We appreciate your questions, and look forward to your bid response!

Mercer County Community College Purchasing Department  
Steven M. Quattro – Director of Purchasing