



Clarification # 2
RFP # 1508
Water Treatment Services

Dear Vendors

The available information regarding the tank located at the Trenton Campus follows; this system is only serviced.

- Pump and pipe information:
171 GPM
70 feet
7.5 H.P.
1800 RPM
3" pipe at pump transitioning to 4" throughout building

The system serves the Kerney Hall which is 4 floors and the Career Center Building which is 3 floors both with a penthouse air handler.

Bidders may bid on all maintenance to include PULSE PURE or excluding PLUSE PURE.

Thank You
Simone Kirchmyer
Purchasing Agent
Mercer County Community College